

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 26/69

Date : 24/2/26.


It is certified that an inspection team headed by **Dy. Civil Surgeon** (Officer designation) from **Health Department** (Name of Department/ Office) inspected **Shreejee International School , 11 Moorti , Murthal Road , Sonipat** on 24/2/26. and found **Shreejee International School , 11 Moorti , Murthal Road , Sonipat** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygiene sanitation condition in the School building & disable friendly campus Facilities as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of **One Year February 2027**

Signature with seal : _____

Name :- _____

Designation :- _____



To

Shreejee International School , 11 Moorti ,

Murthal Road , Sonipat



For Shreejee International School

Dilip Kumar
Manager

Memo No:- 978

Date:- 03/09/2026

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification :	SNP/02180/9/2026 / Private	Sample Details	Date & Time
Sender :	SHREEJEE INTERNATIONAL SCHOOL SONIPAT HARYANA R.	Collected By	Virender
Location :	, 11 Moorti, Murthal Road, Sonipat	Collection Date	19/08/2026 at 14:04
Sample Description :	Drinking Water	Received at lab	01/09/2026 at 10:31
Latitude / Longitude :	77.058282 / 29.018055	Analysis Start Date	01/09/2026
		Analysis End Date	02/09/2026
		Sample Quantity	2 ltrs

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.25	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Color	5.0	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120-B
5	Total Dissolved Solids @ 180°C ± 2°C	128	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCO ₃	60	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium (as Ca)	4.01	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium (as Mg)	12.15	30 mg/lit.	100 mg/lit.	APHA 24th Edition, -3500 Mg B
9	Total Alkalinity	76	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride (as Cl)	29.99	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So ₄	20	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO ₄ -E
12	Fluoride (as F)	0.21	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C/
13	Iron (as Fe)	0.16	1.0 mg/lit.	1.0 mg/lit.	USEPA
14	Nitrate (as NO ₃)	0.5	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D
15	pH @ 25°C	6.60	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED SONIPAT Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found **"CONFORMING"** to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

SONIA, CHEMIST
DISTRICT WATER TESTING LABORATORY, SONIPAT
email:-chemist.sonepat@phedharyana.gov.in

For Shreejee International School
[Signature]
Manager

